

## *Annual Drinking Water Quality Report*

Town of Hagerstown

Public Water Supply #IN5289008

We are very pleased to provide you with this year's Annual Water Quality Report. We want to keep you informed about the excellent water and services we have delivered to you over the past year. Our goal is and always has been, to provide to you a safe and dependable supply of drinking water. Our wells draw ground water *from the Whitewater Valley Aquifer System*. We have a wellhead protection plan available from our office that provides more information such as potential sources of contamination.

I AM PLEASED TO REPORT THAT OUR DRINKING WATER IS SAFE AND MEETS FEDERAL AND STATE REQUIREMENTS.

If you have any questions about this report or concerning your water utility, please contact **Mr. Bob Warner, Town Manager at 765-489-6171**. We want our valued customers to be informed about their water utility. If you want to learn more, please attend any of our regularly scheduled Town Council meetings. They are held on **the first and third Mondays (at 6:30 pm) of each month at the Town Hall located at 49 E. College Street**.

**The Hagerstown Municipal Utilities** routinely monitors for constituents in your drinking water according to Federal and State laws. The following table shows the results of our monitoring for the period of January 1<sup>st</sup> to December 31<sup>st</sup>, **2013**. As water travels over the land or underground, it can pick up substances or contaminants such as microbes, inorganic and organic chemicals, and radioactive substances. All drinking water, including bottled drinking water, may be reasonably expected to contain at least small amounts of some constituents. It's important to remember that the presence of these constituents does not necessarily pose a health risk.

In this table you will find many scientific terms and abbreviations, some of which may require further explanation. To help you better understand these terms we've provided the following definitions:

*Action Level* - the concentration of a contaminant which, if exceeded, triggers treatment or other requirements which a water system must follow.

*Action Level Goal (ALG)* - The level of a contaminant in drinking water below which there is no known or expected risk to health. ALG's allow for a margin of safety.

*Avg* - Regulatory compliance with some MCLs are based on running annual average of monthly samples

*Maximum Contaminant Level (MCL)* - The "Maximum Allowed" (MCL) is the highest level of a contaminant that is allowed in drinking water. MCLs are set as close to the MCLGs as feasible using the best available treatment technology.

*Maximum Contaminant Level Goal (MCLG)* - The "Goal"(MCLG) is the level of a contaminant in drinking water below which there is no known or expected risk to health. MCLGs allow for a margin of safety.

*Maximum Residual Disinfectant Level (MRDL)* -The highest level of a disinfectant allowed in drinking water. There is convincing evidence that addition of a disinfectant is necessary for control of microbial contaminants.

*Maximum Residual Disinfectant Level Goal (MRDLG)* -The level of a drinking water disinfectant below which there is no known or expected risk to health. MRDLGs do not reflect the benefits of the use of disinfectants to control microbial contaminants.

*na* - not applicable.

*Non-Detects (ND)* - laboratory analysis indicates that the constituent is not present.

*Parts per million (ppm) or Milligrams per liter (mg/l)* - one part per million corresponds to one minute in two years, a single penny in \$10,000, or an ounce in 7350 gallons of water.

*Parts per billion (ppb) or Micrograms per liter* - one part per billion corresponds to one minute in 2,000 years, a single penny in \$10,000,000, or an ounce in 7,350,000 gallons of water.

*Picocuries per liter (pCi/L)* - picocuries per liter is a measure of the radioactivity in water.

*Treatment Technique (TT)* - A treatment technique is a required process intended to reduce the level of a contaminant in drinking water.

TEST RESULTS							
Contaminant	Violation Y/N	Level Detected	Range	Unit Measurement	MCLG	MCL	Likely Source of Contamination
<b>Inorganic Contaminants</b>							
Barium Collected 2012	No	0.191	0.191 – 0.191	ppm	2	2	Discharge of drilling wastes; discharge from metal refineries; erosion of natural deposits
Fluoride Collected 2012	No	1.154	1.154 – 1.154	ppm	4	4.0	Erosion of natural deposits; water additive which promotes strong teeth; discharge from fertilizer and aluminum factories
Nitrate (as Nitrogen) Collected 2013	No	3	2.64 – 2.64	ppm	10	10	Runoff from fertilizer use; leaching from septic tanks, sewage; erosion of natural deposits
<b>Volatile Organic Contaminants</b>							
TTHM [Total trihalomethanes] Collected 2013	No	2	1.9 – 1.9	ppb	No goal for total	80	By-product of drinking water disinfection
HAA5 (Total Haloacetic Acids) Collected 2013	No	2	2 – 2	ppb	No goal for total	60	By-product of drinking water disinfection
Chlorine Collected 2013	No	1	0 - 1	ppm	MRDLG = 4	MRDL = 4	Water additive used to control microbes
<b>Radioactive Contaminants</b>							
Uranium Collected 11-16-2010	No	1.1	1.1 – 1.1	ug/l	0	30	Erosion of natural deposits
<b>Lead and Copper</b>							
Contaminant	MCLG	Action Level	# Sites over AL	90 <sup>th</sup> Percentile	Units	Violation	Likely Source of Contamination
Copper Collected 2012	1.3	1.3		0.198	ppm	N	Erosion of natural deposits; leaching from wood preservatives; corrosion of household plumbing systems
Lead Collected 2012	0	15	1	4.7	ppb	N	Erosion of natural deposits; corrosion of household plumbing systems
<b>Coliform Bacteria</b>							
Maximum Contaminant Level Goal	Total Coliform Maximum Contaminant Level	Highest Number of Positive	Fecal Coliform or E. Coli Max. Contaminant Level	Total Number of Positive E. Coli or Fecal Coliform Samples	Violation	Likely Source of Contamination	
0	0 positive monthly samples	0		0	No	Naturally Present in the environment	

*Microbiological Contaminants:*

**Arsenic.** Some people who drink water containing arsenic in excess of the MCL over many years could experience skin damage or problems with their circulatory system, and may have an increased risk of getting cancer.

**Lead.** Infants and children who drink water containing lead in excess of the action level could experience delays in their physical or mental development. Children could show slight deficits in attention span and learning abilities. Adults who drink this water over many years could develop kidney problems or high blood pressure.

**Nitrate.** Infants below the age of six months who drink water containing nitrate in excess of the MCL could become seriously ill and, if untreated, may die. Symptoms include shortness of breath and blue-baby syndrome.

**PCBs** [Polychlorinated biphenyls]. Some people who drink water containing PCBs in excess of the MCL over many years could experience skin damage or problems with their circulatory system, and may have an increased risk of getting cancer.

While your drinking water meets EPA's standard for arsenic, it does contain low levels of arsenic. EPA's standard balances the current understanding of arsenic's possible health effects against the cost of removing arsenic from drinking water. EPA continues to research the health effects of low levels of arsenic, which is a mineral known to cause cancer in humans at high concentrations and is linked to other health effects such as skin damage and circulatory problems. Some people who drink water containing arsenic in excess of the MCL over many years could experience skin damage or problems with their circulatory system, and may have an increased risk of getting cancer.

Nitrate in drinking water at levels above 10 ppm is a health risk for infants of less than six months of age. High nitrate levels in drinking water can cause blue baby syndrome. Nitrate levels may rise quickly for short periods of time because of rainfall or agricultural activity. If you are caring for an infant you should ask advice from your health care provider.

*Some people who drink water containing trihalomethanes in excess of the MCL over many years experience problems with their liver, kidneys, or central nervous systems, and may have increased risk of getting cancer.*

“If present, elevated levels of lead can cause serious health problems, especially for pregnant women and young children. Lead in drinking water is primarily from materials and components associated with service lines and home plumbing. The Hagerstown Municipal Utility is responsible for providing high quality drinking water, but cannot control the variety of materials used in plumbing components. When your water has been setting for several hours, you can minimize the potential of lead exposure by flushing your tap for 30 seconds to 2 minutes before using the water for drinking or cooking. If you are concerned about lead in your water, you may wish to have your water tested. Information on lead in drinking water, testing methods, and steps you can take to minimize exposure is available from the Safe Drinking Water Hotline or at <http://www.epa.gov/safewater/lead>.”

### **What does this mean?**

As you can see by the table, our system had no violations. We're proud that your drinking water meets or exceeds all Federal and State requirements. We have learned through our monitoring and testing that some constituents have been detected. The EPA has determined that your water IS SAFE at these levels.

The sources of drinking water (both tap water and bottled water) include rivers, lakes, streams, ponds, reservoirs, springs, and wells. As water travels over the surface of land or through the ground, it dissolves naturally occurring minerals and, in some cases, radioactive material, and can pick up substances resulting from the presence of animals or from human activity. Contaminants that may be present in source water include:

- Microbial contaminants, such as viruses and bacteria, which may come from sewage treatment plants, septic systems, agricultural livestock operations, and wildlife.
- Inorganic contaminants, such as salts and metals, which can be naturally-occurring or result from urban storm runoff, industrial or domestic wastewater discharges, oil and gas production, mining or farming.
- Pesticides and herbicides, which may come from a variety of sources such as agriculture, storm water runoff, and residential uses.
- Organic chemical contaminants, including synthetic and volatile organic chemicals, which are by-products of industrial processes and petroleum production, and can, also come from gas stations, urban storm water runoff, and septic systems.
- Radioactive materials, which can be naturally occurring or be the result of oil and gas production and mining activities.

In order to ensure tap water is safe to drink, EPA prescribes regulations that limit the amount of certain contaminants in water provided by public water systems. Food and Drug Administration (FDA) Regulations establish limits for contaminants in bottled water, which must provide the same protection for public health.

All sources of drinking water are subject to potential contamination by substances that are naturally occurring or man made. These substances can be microbes, inorganic or organic chemicals and radioactive substances. All drinking water, including bottled water, may reasonably be expected to contain at least small amounts of some contaminants. The presence of contaminants does not necessarily indicate that the water poses a health risk. More information about contaminants and potential health effects can be obtained by calling the Environmental Protection Agency's Safe Drinking Water Hotline at 1-800-426-4791.

MCL's are set at very stringent levels. To understand the possible health effects described for many regulated constituents, a person would have to drink 2 liters of water every day at the MCL level for a lifetime to have a one-in-a-million chance of having the described health effect.

**Nitrates:** As a precaution we always notify physicians and health care providers in this area if there is ever a higher than normal level of nitrates in the water supply.

**Lead:** Lead in drinking water is rarely the sole cause of lead poisoning, but it can add to a person's total lead exposure. All potential sources of lead in the household should be identified and removed, replaced or reduced.

Thank you for allowing us to continue providing your family with clean, quality water this year. In our continuing efforts to maintain a safe and dependable water supply it may be necessary to make improvements in your water system. The costs of these improvements may be reflected in the rate structure. Rate adjustments may be necessary in order to address these improvements. Thank you for understanding.

Some people may be more vulnerable to contaminants in drinking water than the general population. Immuno-compromised persons such as persons with cancer undergoing chemotherapy, persons who have undergone organ transplants, people with HIV/AIDS or other immune system disorders, some elderly, and infants can be particularly at risk from infections. These people should seek advice about drinking water from their health care providers. EPA/CDC guidelines on appropriate means to lessen the risk of infection by cryptosporidium and other microbiological contaminants are available from the Safe Drinking Water Hotline (800-426-4791).

We at the **Hagerstown Municipal Utilities** spend many hours working to provide top quality water to every tap. We ask that all our customers help us protect our water sources, which are the heart of our community, our way of life and our children's future. Please call our office if you have questions.

TOWN OF HAGERSTOWN

49 East College Street  
Hagerstown, Indiana 47346